

To: Board of Education

From: Tony Barron, executive director, business & operations, ext. 1643

Re: Installation of Fire Doors – Broken Arrow/South Cafeteria

Date: August 4, 2016

Background:

The State Fire Marshal conducted a districtwide inspection in August 2015. During that inspection, violations were discovered and an order to comply was issued concerning existing fire door systems at the Broken Arrow Elementary School/South Middle School cafeteria.

The existing fire door systems do not meet NFPA 80 fire code. The doors close at an unsafe speed and are not connected to the building fire control system. Replacement is necessary for the protection of students and staff. The costs and locations are identified below and are coming to the board for approval. The bid was procured through the Kansas State Contract # 39103.

Main Entrance to Cafeteria	\$9,410
South Dish Return	9,224
Broken Arrow Dish Return	<u>8,359</u>
Total	\$26,993

Recommendation:

The Facility Planning Committee recommends board approval of a contract with Overhead Door Company of Kansas City for the installation of fire doors at the Broken Arrow/South cafeteria.

Motion:

"I move the Board of Education approve a contract with Overhead Door Company of Kansas City in the amount of \$26,993 for the installation of fire doors at the Broken Arrow Elementary School/South Middle School cafeteria."